

CERTIFICATE

Issued to:
Applicant:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Licensee:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Product : Switching Power supply
Trade name(s) : MEAN WELL
Type(s)/model(s) : CSP-3000-120, CSP-3000-250 and CSP-3000-400

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 62368-1:2014 and EN 62368-1:2014/A11:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6059480


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 4 June 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-130804 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



35-130804

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Switching Power supply
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: CSP-3000-120, CSP-3000-250 and CSP-3000-400
Input voltage	: 200 – 240 V~
Rated frequency	: 50/60 Hz
Input current	: 20 A
Output power	: 3000 W

Product data – type CSP-3000-120

Output voltage	: 90 – 120 Vdc
Output current	: 25 – 30 A

Product data – type CSP-3000-250

Output voltage	: 120 – 250 Vdc
Output current	: 12 – 17 A

Product data – type CSP-3000-400

Output voltage	: 200 – 400 Vdc
Output current	: 7,5 – 10 A

TESTS**Test requirements**

EN 62368-1:2014
EN 62368-1:2014/A11:2017

Test result

The test results are documented in DEKRA test file 491888700.

Additional information

This certificate replaces certificate No. 35-130804 which we hereby declare invalid.

The list of components is laid down in test report 4918887.51.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District
510890 Guangzhou Guangdong, China