

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Built-in controlgear
Name and address of the Applicant Nom et adresse du demandeur	Mean Well Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the manufacturer Nom et adresse du fabricant	Mean Well Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the factory Nom et adresse de l'usine	Mean Well (Guangzhou) Electronics Co., Ltd. 2F, A Building, Yuean Industrial Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, Guangdong China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Built-in type, SELV, Constant current mode HBG-60-2100P: Input: 100-240 V, 50/60 Hz, 0,7 A, PF 0,95, ta 50 °C Output: 2100 mA, 19-29 Vdc, max 35 Vdc HBG-60-1400P: Input: 100-240 V, 50/60 Hz, 0,7 A, PF 0,95, ta 50 °C Output: 1400 mA, 28-43 Vdc, max 50 Vdc HBG-60-1050P: Input: 100-240 V, 50/60 Hz, 0,7 A, PF 0,95, ta 50 °C Output: 1050 mA, 37-55 Vdc, max 60 Vdc
Trademark (if any) Marque de fabrique (si elle existe)	
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	HBG-60-1050P HBG-60-1400P HBG-60-2100P
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61347-1(ed.2);am1;am2 61347-2-13(ed.1)
National differences / Comments Les différences nationales / Commentaires	EU Group Differences, AU

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2014-12-18

Signature: A.P. van der Veen

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES  
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS  
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

As shown in the test report Ref. No. which forms part of this certificate  
Comme indiqué dans le rapport d'essais numéro de référence qui constitue  
partie de ce certificat

2175773.51

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.,  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2014-12-18

Signature: A.P. van der Veen

A handwritten signature in blue ink, appearing to be "A.P. van der Veen".

Additional factory

Mean Well Enterprises Co., Ltd.

No.28, Wuquan 3 rd, Wugu Dist, New Taipei City 248

Taiwan

Suzhou Mean Well Technology Co., Ltd.

No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,  
Xiang-cheng Dist, Suzhou, 215152 Jiangsu

China

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2014-12-18

Signature: A.P. van der Veen

A handwritten signature in blue ink, appearing to be "A.P. van der Veen", written over a blue circular stamp or watermark.