



Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: KNX-40E-1280D,KNX-40E-1280

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU)

Low Voltage Directive (2014/35/EU) :

EN IEC 61558-1:2019

EN 61558-2-16:2009+A1:2013

Dekra certificate No : 35-123396

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission EN 50491-5-2:2010 / EN 50491-5-3:2010 / EN IEC 63044-5-2:2019/ EN IEC 63044-5-3:2019

Radiated emission EN 50491-5-2:2010 / EN 50491-5-3:2010 / EN IEC 63044-5-2:2019/ EN IEC 63044-5-3:2019

Harmonic current EN IEC 61000-3-2:2019 + A1:2021

Voltage flicker EN 61000-3-3:2013 + A1:2019 + A2:2021

EMS (Electro-Magnetic Susceptibility)

EN 50491-5-2:2010 EN 50491-5-3:2010 EN IEC 63044-5-2:2019 EN IEC 63044-5-3:2019

ESD air EN 61000-4-2:2009 Level 3 8KV

ESD contact EN 61000-4-2:2009 Level 2 4KV

RF field susceptibility EN IEC 61000-4-3:2020 Level 3 10V/m

EFT bursts EN 61000-4-4:2012 Level 3 2KV/5KHz

Surge susceptibility EN 61000-4-5:2014 + A1:2017 Level 3 1KV/Line-Line

Surge susceptibility EN 61000-4-5:2014 + A1:2017 Level 3 2KV/Line-Earth

Conducted susceptibility EN 61000-4-6:2014 Level 3 10V

Magnetic field immunity EN 61000-4-8:2010 Level 4 30A/m

Voltage dip, interruption EN IEC 61000-4-11:2020 100% dip 1 periods 60% dip 10 periods 30% dip 25 periods 100% interruptions 250 periods

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number GC2xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

Aries
(Signature)

Alex Tsai/Director, Product Strategy Center :

(Name / Position)

[Signature]
(Signature)

Taiwan

(Place)

Jun. 29th, 2022

(Date)