



# Certificate of Compliance

**Certificate:** 80230943 **Master Contract:** 302258  
**Project:** 80230943 **Date Issued:** 2024-11-12  
**Issued to:** Mean Well Enterprises Co., Ltd.  
No 28 Wuquan 3rd Rd  
Wugu Dist, New Taipei City 24891  
Taiwan  
**Attention:** Eason Chung

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Cary Hsieh  
Cary Hsieh

## PRODUCTS

Class 5311 67 POWER SUPPLIES - Component Type (CSA 62368-1)  
Class 5311 97 POWER SUPPLIES - Component Type (UL 62368-1) - Certified to US Stds

### **True Sine Wave Inverter**

Model(s)	Rating
NTS-x-yz (x=300 or 450, y=112, 124 or 148, z= US or GFCI)	See below for details.

Model No.	DC input rating	AC output rating
NTS-300-112z	12 Vdc, 30 A	Default 110 Vac, 60 Hz, 2.72 A; 100/110/115/120 Vac, 50/60 Hz selectable
NTS-300-124z	24 Vdc, 15 A	Default 110 Vac, 60 Hz, 2.72 A; 100/110/115/120 Vac, 50/60 Hz selectable
NTS-300-148z	48 Vdc, 8 A	Default 110 Vac, 60 Hz, 2.72 A; 100/110/115/120 Vac, 50/60 Hz selectable



**Certificate:** 80230943

**Master Contract:** 302258

**Project:** 80230943

**Date Issued:** 2024-11-12

NTS-450-112z	12 Vdc, 50 A	Default 110 Vac, 60 Hz, 4.09 A; 100/110/115/120 Vac, 50/60 Hz selectable
NTS-450-124z	24 Vdc, 25 A	Default 110 Vac, 60 Hz, 4.09 A; 100/110/115/120 Vac, 50/60 Hz selectable
NTS-450-148z	48 Vdc, 14 A	Default 110 Vac, 60 Hz, 4.09 A; 100/110/115/120 Vac, 50/60 Hz selectable

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 62368-1:19+Upd.1 (Third Edition) - Audio/video, information and communication technology equipment — Part 1: Safety requirements - Third Edition; Update No. 1: October 2021

UL 62368-1:2019 - Third Edition - UL Standard for Safety Audio/video, information and communication technology equipment – Part 1: Safety requirements - Including revisions through October 22, 2021



**Certificate:** 80230943


**Master Contract:** 302258

**Project:** 80230943

**Date Issued:** 2024-11-12

Notes:

Products certified under Class(es) C531167, C531197 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 80230943

**Master Contract:** 302258

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80230943	2024-11-12	UL/CSA 62368-1 3rd edition for NTS-x-yz (x=300 or 450, y=112, 124, 148, z= US, GFCI when y=112, 124 or 148), based on CB# NL-71641 (IEC 62368-1:2014)