



Declaration of Conformity			
For the following equipment:			
Product Name: Switching Power Supply			
Model Designation: PS-05-X (X=5,12,15,24,48)			
is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:			
RoHS Directive (2011/65/EU)、(EU)2015/863 Low Voltage Directive (2014/35/EU):			
EN 62368-1:2014+A11	TUV certificate No: R50455178		
Electromagnetic Compatibility Directive (2014/30/EU): EMI (Electro-Magnetic Interference) Conducted emission / Radiated emission EN 55032:2015+A11:2020+A1:2020 Class B			
Harmonic current	EN IEC 61000-3-2:2019+A1:202	21	
Voltage flicker	EN 61000-3-3:2013+A1:2019+A2:2021		
EMS (Electro-Magnetic Susceptibility)			
EN 55035:2017+A11:2020			
ESD air	EN 61000-4-2:2009	Level 3	8KV
ESD contact	EN 61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN IEC 61000-4-3:2020	Level 2	3V/m
EFT bursts	EN 61000-4-4:2012	Level 2	1KV/5KHz
Surge susceptibility	EN 61000-4-5:2014+A1:2017	Level 3	1KV/Line-Line
Surge susceptibility	EN 61000-4-5:2014+A1:2017	Level 3	2KV/Line-Earth
Conducted susceptibility	EN 61000-4-6:2014	Level 2	3V
Magnetic field immunity	EN 61000-4-8:2010	Level 2	3A/m
Voltage dip, interruption	EN IEC 61000-4-11:2020 >95% dipperiods	o 0.5 periods 30% di	p 25 periods >95% interruptions 250
Note: A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure. For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on http://www.meanwell.com)".			
This Declaration is effective from serial number SC4xxxxxxx			
Person responsible for marking this declaration:			
MEAN WELL Enterprises Co., Ltd. (Manufacturer Name) No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan			
(Manufacturer Address)			
Aries Jian/ Director, Group R&D: // Y(e) Alex Tsai/Director, Product Strategy Center: (Signature) (Name / Position)			

Aug. 21st, 2024

(Date)

Taiwan (Place)